


Consumption measurement



Conversion of consumption data at different temperatures



$$V_{60} = \frac{V_{\text{meas}} \cdot (t_{\text{meas}} - t_{\text{cw}})}{60 \text{ °C} - t_{\text{cw}}}$$

V_{60} Consumption at 60 °C [l]

V_{meas} Measured consumption [l]

t_{meas} Measured temperature [°C]


t_{cw} Cold water temperature [°C]

$$V_x = \frac{V_{60} \cdot (60 \text{ °C} - t_{\text{cw}})}{t_x - t_{\text{cw}}}$$

V_x Consumption at temperature x °C [l]

t_x Desired temperature [°C]

Hot water consumption in different institutions




Example of a circulation pipe with a single length of 24 m

$\Delta T(F / R) = 5 \text{ K}$

$T_{\text{feed flow}} = 55 \text{ °C}$

$T_{\text{amb.}} = 20 \text{ °C}$



Pipe: 28 x 1,5

Insulation: 100 %

$\lambda = 0.05 \text{ W}/(\text{m}\cdot\text{K})$

Suspension of circulation:

22⁰⁰–6⁰⁰



Theoretic linear pipe losses: 0.2 W/(m·K)

Realistic linear losses: 0.5 W/(m·K)

Thermal energy: 4.5 MWh/a

Dimensioning of the collector surface



Capacity utilisation	Institution	Collector surface
30–50 l/(m ² ·d)	One family house	4–8 m ²
40–70 l/(m ² ·d)	Small multiple family dwelling	2–4 m ² / accomm. unit
60–80 l/(m ² ·d)	Large multiple family dwelling	1–1.5 m ² / accomm. unit
60–80 l/(m ² ·d)	Residential homes	0.5–0.8 m ² / place
60–80 l/(m ² ·d)	Hospital	ca. 1 m ² / bed
60–80 l/(m ² ·d)	Hotel	0.5–1.5 m ² / bed
60–80 l/(m ² ·d)	Youth hostel	0.5–1 m ² / bed
60–80 l/(m ² ·d)	Canteen (kitchens)	ca. 1 m ² / 10 meals

These indications are benchmarks for a rough dimensioning that is later tested and optimised through simulating calculations.


Dimensioning of the storage tanks




Benchmark: ≥ 50 litres per m² collector surface

- Depending on
- the type of storage tank
 - the maximum storage temperature
 - the consumption profile
 - the aspired solar fraction

Consumption profile



Maximum at noon



Maximum in the morning & evening

Specific flow rate

Flow variant	Spec. volumetric flow rate	Heating at 1,000 W/m ² *
High flow	40-60 l/(m ² ·h)	13- 8.6 K
Medium flow	20-40 l/(m ² ·h)	26-13 K
Low flow	12-20 l/(m ² ·h)	43-26 K

* at 60 % efficiency

Total volumetric flow rate in the collector loop:


$$\dot{V} = \text{specific volumetric flow rate} \cdot \text{collector surface}$$

Adjustment of the collector circuit

- Mixture water/glycol: appropriate dosage, in order to resist the norm outside temperature (-25 °C)
 $T_{\text{Calculation}} - 10 \text{ °C}$
- Low flow: 12 ... 20 l/(m²·h)
- Copper pipes:

Flow [l/h]	Outer diameter x thickness [mm]
600 - 900	28 × 1.5
800 - 1,500	35 × 1.5
1,500 - 2,000	42 × 1.5
2,000 - 3,200	54 × 2
3,200 - 5,000	64 × 2
5,000 - 7,000	76.1 × 2
7,000 - 10,000	88.9 × 2

Antifreeze



© target GmbH

V Design and dimensioning


Source: Tyforop

11

Dimensioning of pipes (II)



Pressure loss per pipe metre for glycol with 40 % at 40 °C



© target GmbH

V Design and dimensioning

Source: Förderverein für Neue Technik

12

Plate heat exchanger, counter flow (without heat losses)

$$\dot{Q} = (k \cdot A) \cdot \Delta T_m$$

$$\dot{Q} = \dot{m}_1 \cdot c_{p,1} \cdot (T_{1,in} - T_{1,out}) = \dot{m}_2 \cdot c_{p,2} \cdot (T_{2,out} - T_{2,in})$$

with $\dot{m}_1 \cdot c_{p,1} = \dot{m}_2 \cdot c_{p,2}$ follows $\Delta T_m = (T_{1,in} - T_{2,out}) = (T_{1,out} - T_{2,in})$


Nominal capacity of collector field

$$\dot{Q} = \eta_{coll.} \cdot 800 \text{ W/m}^2 \cdot A_{coll.}$$

with $\eta_{coll.} = \eta_{coll.} (800 \text{ W/m}^2, 30 \text{ K})$

$\Delta T_{log} = 5 \text{ K}$ (selected)

Heat exchanger in collector loop



Price of usable solar heat





Photo: Ambiente Italia

Dimensioning of heat exchangers (III)

- Boiler performance according to appropriate calculation methods
- $P_{\text{Heat exchanger}} = P_{\text{Boiler}}$
- $\Delta T_{\text{log}} = 5 \text{ K}$




Pressure losses in the collector loop

Example: Calculation of the pressure loss in the collector loop

Collectors (4 modules, 70 mbar each)	280 mbar
Pipes (Copper, 35 x 1.5, l = 60 m)	54 mbar
Heat exchanger	100 mbar
Mountings etc. (10 % pipes)	5 mbar
Total	439 mbar

Dimensioning of the pumps



© target GmbH

V Design and dimensioning


Source: Grundfos

17

Dimensioning of the diaphragm expansion tank (I)



Identification of the expansion volume



© target GmbH

V Design and dimensioning

Source: M. Schnauss

18

Adjustment of pressure in the collector loop

p_i (initial) = mm of water + 0.5 bar

p_{DET} (Pre-pressure of diaphragm expansion tank)
= p_i - ca. 0,5 bar

p_f (final) = 5.5 bar

p_{SV} (Safety valve) = p_f + 0.5 bar

recommended

2.5 bar up to
20 m difference of height

2 bar

5.5 bar

6 bar

- Check, that $(p_f - p_i) / (p_f + 1 \text{ bar})$ not $\gg 0.5!$
- All building components / circuit components should be dimensioned for 7 bar

Dimensioning of the expansion tank


Content of the collector loop: $V_{fluid} = V_{Coll.}$ (Collector)
 $+ V_p$ (Pipes)
 $+ V_{HE}$ (Heat exchanger)
 $+ V_{oth.}$ (other components)

Thermal expansion: $\Delta V_{fluid} = e \cdot V_{fluid}$ (e = 0.045 water; 0.07 mixture)

Useable volume: $V_{use} = (\Delta V_{fluid} + V_{Coll.}) \cdot (1,5 \dots 2,0)$ (safety factor)

Nominal volume: $V_{nom.} = V_{use} \cdot (p_f + 1) / (p_f - p_i)$

Infeed tanks



© target GmbH

V Design and dimensioning

Source: Solarpraxis

21

Safety valves



maximum pressure $p_{\max} = 6 \text{ bar}$

$$T_{\text{sv}} = T' (7 \text{ bar}_{\text{abs}}) = 165,3 \text{ °C}$$

$$\dot{Q}_{\text{sv}} = \eta_{\text{coll}} \cdot 1.100 \text{ W/m}^2 \cdot A_{\text{coll}}$$

$$\text{mit } \eta_{\text{coll}} = \eta_{\text{coll}} (1.100 \text{ W/m}^2, 135 \text{ K})$$



Diameter

Capacity [kW]	50	100	200	350	600	900
Diameter DN [mm]						
Inlet	15	20	25	32	40	50
Outlet	20	25	32	40	50	65


© target GmbH

V Design and dimensioning

Source: ITW

22

Control unit



© target GmbH

V Design and dimensioning

Source: Ambiente Italia

23

Sensor



Heat insulation?

Sensor length?

© target GmbH

V Design and dimensioning

24